



NOTES:

1. THE ENTIRE INSTALLATION MUST BE INSPECTED AND APPROVED BY THE MATR REPRESENTATIVE AND THE ALLEGHENY COUNTY COUNTY HEALTH DEPT.
2. ALL MATERIALS MUST BE INSTALLED IN ACCORDANCE WITH THE ALLEGHENY COUNTY PLUMBING CODE AND IN ACCORDANCE WITH THE MATR RULES AND REGULATIONS.
3. BEFORE WORK IS STARTED A PLAN MUST BE FILED WITH THE ALLEGHENY COUNTY HEALTH DEPT. PLUMBING DIVISION AND AN APPLICATION MUST BE FILED WITH MATR
4. CLEAN OUTS SHALL BE INSTALLED AT 50' MAXIMUM INTERVALS FOR 4" LINES OR 100' MAXIMUM INTERVALS FOR 6" LINES AND AT CHANGES OF DIRECTION GREATER THAN 45°.
5. TRANSITION BETWEEN 4" WYE AND 6" PIPE MUST BE MADE IN 18" MAXIMUM. (APPLICABLE TO LATERALS WHICH ARE 6" IN SIZE DOWNSTREAM OF TRANSITION.)
6. VERTICAL RISER INSTALLED AS REQUIRED BY THE MATR RULES AND REGULATIONS.
7. ALL PIPING AND FITTINGS SHALL BE SDR 35 PVC OR SCH. 40 PVC OR STD. WEIGHT CAST IRON.
8. THIS DETAIL (EXHIBIT I-A) IS APPLICABLE TO NEW BUILDING CONSTRUCTION WHERE THE LATERAL IS GREATER THAN 6' DEPTH.
9. ANY LINES INSTALLED IMPROPERLY OR COVERED WITHOUT INSPECTION MUST BE REMOVED OR UNCOVERED AT THE PROPERTY OWNER'S EXPENSE.

**EXHIBIT I-A
MATR STD. S-06-A**

THE MUNICIPAL AUTHORITY OF THE TOWNSHIP OF ROBINSON	
SANITARY SEWER LATERAL CONNECTION	
NIRA Consulting Engineers, Inc.	
DATE: 02-05-08	FILE: MATR S-06 IA